Test Reports

AARVI MARKETING PVT LTD

SITE TEST REPORT

Test Requested By: **Magicrete Building Solutions Pvt Ltd**

Site Address: Block No 188, B-190,192 Post – Arak , Tal – Jalalpore Navsari, 396475 Gujarat

Project Contact: **Mr. Saurabh Srivastava**

Email/ Phone: 8511194045

Product(s) Tested: **SMNKC 6x60 & KPS FAST 8x80 & SM 8x100**

Product(s) Set By: Mr. Akash Jariwala

Test Location: Jalalpore Navsari , Gujarat Internal / External Internal

Application Details: Fixtures on AAC Wall Panel

RESULT

TEST NO.	PRODUCTS TESTED	BASE MATERIAL	REQUIRED LOAD	TESTED LOAD	REMARKS (Proof / observed load)
1.	SMN 6x40	AAC Wall Panel	0.5 Kn	0.90 Kn	No Failure
2.	KPS FAST 8x80	AAC Wall Panel	0.5 Kn	3.3 Kn	NO Failure
3.	SM 8x100	AAC Wall Panel	0.5 Kn	0.80 Kn	NO Failure

Comments: **The load witnessed was more than required load**

Installation Information:

Fastener Installed by: Akash Jariwala	Installation date: 19.01.2021
Borehole Diameter (mm): 5mm for 6mm dia anchor & 8mm for 8mm dia anchor	Borehole drilling : Rotary Mode
Borehole depth: 70 mm & 90 mm & 110 mm	Borehole Cleaning: No cleaning
Tightening torque (Nm):	Borehole Conditions: Dry

Test Witnessed By:

Company	Name	Function
Magicrete Building Solution Pvt Ltd	Mr. Saurabh Srivastava	Technical Head
KLIMAS	Mr. Smit Tiwary	Sales Manager (WEST)
AARVI MARKETING PVT LTD	Mr. Akash Jariwala	Sales Leader

Test Conducted By: Name: Akash Jariwala Position: Sales Leader

Equipment Details: Tester: Hydrajaws 2000 Type: Digital Gauge No: MAN2844
Gauge Type: Digital

Test Date: 19.01.2021