GEO DESIGNS & RESEARCH (P) LTD.

GEO TEST HOUSE
(A DIV. OF GEO DESIGNS & RESEARCH (P) LTD.)

TEST REPORT

Job No : 602-112002 Report No : NV3/602-112002/BLK/1120005-07

Sample No : 1120005-07 Report Date : 24/07/2021

Client : Magicrete Building Solution Pvt. Ltd.

Contractor : -

Consultant : -

Name of Work : Only Quality Check.

Reference No. : Letter Date:- 21/07/2021

Material Description : Autoclaved Areated Concrete Wall Panel Sampled submitted by : Client

Manufacture : Magicrete Size of sample Received: 600mm X 200mm X 100mm

Nos.of Block received : 03 Nos. Date Test Started : 22-07-2021

Date of Sample received : 21-07-2021 Date Test Completed : 24-07-2021

Sr. No.	Lab Sample No	Water Absorption (%)
1	1120005	26.6
2	1120006	27.4
3	1120007	27.9
	Average	**27.3**

Test Method : IS 2185 (Part-1) : 2005 (Reaffirmed Year : 2015)

Tested by : TP

Technical Manager

GEO TEST HOUSE An ISO 9001-2008 Certified Material Testing laboratory NAVSARI, gthnavsari@gmail.com

Authorized Signatory

NOTE:

1. This certificate or report may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the Director, GEO TEST HOUSE, Vadodara.
2. This test certificate applies only to the samples received in the laboratory.

Head Office :
B-10, Krishna Industrial Estate, Opp. B.I.D.C.
Gorwa Estate, Vadodara - 390 016. Gujarat, India.
PH. : +91-265-2290222 M : +91 93746 90024
E-mail : info@geogroup.in / lab@geogroup.in

Navsari Office :
C1B32, Opp. Bank of Baroda, Navsari GIDC,
Sisodara, Navsari - 396424. Gujarat, India.
Ph. : +91-2637-265023. M : +91 93746 90023
Email : navsari@geogroup.in / gthnavsari@gmail.com

www.geogroup.in

IBS INTERNATIONAL BUSINESS SYSTEMS
ISO 9001:2015 Registered